



**Risk Assessment - Use of Gas Torches**

Reference No: CON-44519-8  
 Version No: 2  
 Assessment Approver: Kevin 'Kev' Jarvis

Department: Construction and Maintenance  
 Date Of Assessment: 19 November 2021  
 Review Due Before: 10 April 2027  
 Lead Assessor: Chris Helm  
 Team: Jim Hitchen & Kevin Jarvis

**Use of gas torches**

Type	Hazard Cause	Persons Affected	Control Measures	L Overall	S =	T	Additional Control Measures	L Overall	S =	T	Owner/Action
Health and Safety	Burns or damage caused by naked flame Improper use or failure of equipment	Volunteers & Staff	1) CRITICAL - Engineering: All equipment must be visually checked before each use - Effective 2) CRITICAL - Engineering: Protect items in close proximity to the work area with heat resistant materials - Effective 3) CRITICAL - Engineering: All gas cylinders must remain upright when being transported or in use. - Effective 4) CRITICAL - Engineering: Never roll gas cylinders or drop them - Effective 5) CRITICAL - Administrative: Fire extinguishers or other fire fighting equipment must be available. - Effective 6) CRITICAL - Administrative: Equipment must only be used in a well ventilated area - Effective 7) CRITICAL - Administrative: All flammable materials are to be removed from the work area - Effective 8) CRITICAL - Administrative: Following the directions given in the Safe System of Work for Gas Torches document. - Effective 9) CRITICAL - Administrative: Do not open the valve of unconnected cylinders. - Effective 10) CRITICAL - Administrative: Store gas cylinders in well ventilated areas and away from heat sources. - Effective 11) CRITICAL - PPE: Safety footwear, gloves, overalls and eye protection to be worn - Effective	2 x	3 =	6	1) Engineering: Consider using a trolley with a securing chain for larger cylinders. - Effective 2) Administrative: Use proper lifting techniques when handling gas cylinders. - Effective 3) Administrative: Hoses and regulators should be replaced approximately every 5 years. - Effective 4) Administrative: Any area where hot work has been undertaken should have a fire-watcher in place for one hour after the work has finished. - Effective 5) PPE: Consider using a full face mask for protection. - Effective 6) PPE: Consider wearing flame retardant overalls. - Effective	2 x	3 =	6	n/a

**Score and Control Measure Notes.**

Risk is medium due to possibility of starting a fire  
 Risk remains medium

**COSHH Assessments**

There are no COSHH assessments associated with this risk assessment.  
 Ends



## Appendix



Reference: UI-44519-916  
Gas Torch -



Reference: UI-44519-561  
Gas Torch & Bottle -