Gloucestershire Warwickshire Steam Railway Plc

Kerosene

COSHH Assessment Details

Assessment Id:	COSHH-43998-83	**Lead Assessor:**	Kevin Jarvis
Version No:	3	**Published Date:**	11 April 2024
Status:	Active	**Review Date:**	11 April 2027
Assessment Date:	11 April 2024	**Approved By:**	Kevin 'Kev' Jarvis

Substance Details

Substance Name:	Kerosene	**Substance Use:**	General purpose fuel used predominantly in DMU heaters.
Manufacturer	Mabanaft Ltd	**Emergency Tel No:**	0207 802 3300
Address:	20th Floor, Portland House, Bressenden Place, London. SW1E 5BH.		
Form Of Substance:	Liquid & Vapour	**Routes of Exposure**	Inhalation, Ingestion, Skin, Eyes,
Storage and Handling	Stored in on site fuel storage tank & DMU heater tanks.		

Exposure Limits

WEL: 200 mg/m3 **LEL:** Unknown **SEL:** 300 mg/m3

Substance Classifications



Harmful



Serious long term health hazard



Flammable



Dangerous to the enviroment

Health Phrases

H226 - Flammable liquid and vapour.
H304 - May be fatal if swallowed and enters airways.
H315 - Causes skin irritation.
H336 - May cause drowsiness or dizziness.
H411 - Toxic to aquatic life with long lasting effects.

Precautionary Phrases

P102 - Keep out of reach of children.
P210 - Keep away from heat, hot surfaces, sparks, open flames and other ignition sources. No smoking.
P280 - Wear protective gloves/protective clothing/eye protection/face protection.
P301 + P310 - IF SWALLOWED: Immediately call a POISON CENTER/doctor/999
P331 - Do NOT induce vomiting.
P501 - Dispose of contents/container via an approved disposal route

Required Personal Protection Equipment (PPE)


Gloves


Overalls


Goggles

Control Measures

Current:
• Administrative - Follow the precautionary phrases as described. - Effective
Potential:
No Potential Control Measures
Score Notes:

Assessment Score

Liklihood of Harm:
Not Set

Severity of Harm:
Not Set

Overall:
No Rating Avaiable

Reference Documents

Kerosene - Kerosene Data Sheet